

KING ABDULLAH UNIVERSITY OF SCIENCE AND TECHNOLOGY



Transmittal Form

Project Name: SSOIEI
Contract # PR2855

جامعة الملك عبد الله
للعلوم والتقنية
King Abdullah University of
Science and Technology



PDEC-4-005-F1 Version 1

From: Eng. Mohamed Mekki Bouzidi Project Manager KAUST Project Name: SSOIEI Contractor Company Name: Macc Contractor Address: Riyadh	Transmittal PR2855-MSS-M-318-01	Date: 25-09-2023
--	---	--------------------------------

Transmission of Drawings, Documents, Samples, etc.	DELIVERY	SUBMITTED FOR	CODE
To: Eng. Krishnraja Kinialevoor Project Manager, KAUST Project Name: SSOIEI Address: HRP Site Office	_____ Courier _____ Recipient Messenger _____ Other _____	APPROVAL	1
		INFORMATION	2
		COORDINATION	3
		CLARIFICATION	4
		HANDLING	5

<input type="checkbox"/> Architectural <input type="checkbox"/> Structural <input type="checkbox"/> Civil <input type="checkbox"/> Mechanical <input checked="" type="checkbox"/> HVAC <input type="checkbox"/> Electrical <input type="checkbox"/> Instrumentation/ IT <input type="checkbox"/> Low Current System <input type="checkbox"/> Fire Protection <input type="checkbox"/> Others	APPROVED A APPROVED AS NOTED B REVISE & RESUBMIT C REJECTED D FOR RECORDS ONLY E
--	---

Item No.	Qty.	Document Reference No.	Rev	Document Description	Type	Code	
						Submittal	Action
1	1	PR2855-MSS-M-318	01	Material Specification Submittal for Chilled Water Pumps Manufacturer: Grundfos & Vendor : Al Mousa (SOFTCOPY ATTACHED)	MSS	01	

Type: SD – Shop Drawing RLD – Redline Drawing ABD – As-Built Drawing MSS – Material Specification Submittal
 MS – Method Statement GS - General Submittal OT – Others SM – Samples CT - Certificates

Comments/Instruction/Remark:
 The motor power (11 Kw) not as per the design requirements 5.5 Kw. However, we can proceed since the design team cant find the required power and meet the design requirement the head, pressure and flow rate with the same design power from different supplier in Saudi arabia. So we recommend to edit the energy modelling as per new motor parameter.

We certify that the above submitted items have been reviewed in details and are correct and in strict conformity with the contract except as otherwise stated hereon.

Reviewed By: Eng. Mohammad Mikki Bouzidi Position: Project Manager Date: 25-09-2023	Receipt Information: Name of DC Representative PDEC Project Document Controller	Received By : Date : KAUST DC RECEIVING STAMP
Signature: 	Signature:	
Reviewed By: LEED Consultant Name : Bassel Darwish Position: Technical Manager	Reviewed By: ZAK Designer Name: Eng. Zaid Bamia Position: Technical Engineer Date: 25-09-2023	
Signature: 	Signature:	