

12 NEOM Community Expansion

NEOM Spare
NEOM
Saudi Arabia



نيوم NEOM

MAIL TYPE
Workflow Transmittal

MAIL NUMBER
NOP-WTRAN-077665

REFERENCE NUMBER
NOP-WTRAN-077665

Final (WF-011622) 4100015370/000 - Material Submittal_R05 (MAT/FPR - NEC Provision of Event Support Facility - BSC)

From Mr Mohammed Raziuddin - NEOM - Operations
To (5) Mr Kashif Ali - NEOM - Operations (+4 more...)
Cc (6) Mr Shahbaz Iftikhar - Bridge Saudi Company (+5 more...)
Sent Monday, 9 September 2024 10:01:41 AM AST (GMT +03:00)
Status N/A

DOCUMENT ATTACHMENTS (1)

File	Document No	Revision	Revision Date	Title	Status
	12-900000-4100015370-BSC-FPR-MAT-000006	01	05/09/2024	Material Submittal of Fire Fighting Pump (1500 GPM) (Supplier: AL MOUSA TRADING CO)	B - Incorporate Comments - Proceed

MESSAGE

Workflow Review History

The attached documents have completed the "4100015370/000 - Material Submittal_R05 (MAT/FPR - NEC Provision of Event Support Facility - BSC)" workflow with the following results :

This transmittal was automatically generated.

Doc No	Step	Participant	Review Outcome	Comments
12-900000-4100015370-BSC-FPR-MAT-000006	PMT Review	A Saati	A - Work May Proceed	
	QA/QC MEC Review	K Ali	B - Incorporate Comments - Proceed	Fire Fighting Pumps are classified as CRITICALITY C3 Materials in the NEOM Material List. Pump Performance curve and test reports shall be